

City of Parkville, Missouri
Community Development Department
Division of Building Safety


8880 Clark Avenue
Parkville, MO 64152
(816) 741-7676
(816) 741-0013 FAX

BARBECUE GRILLS

NEW FIRE CODE CHANGES AIM TO REDUCE FIRES FROM BARBECUE GRILLS – Everyone loves a barbecue. Gas and charcoal BBQ cooking grills have become an essential part of our lifestyle. Unfortunately, cooking on gas and charcoal grills can also be dangerous. The use and storage of solid fuel or propane cooking equipment on patios and balconies has resulted in a number of major fires in the state of Vermont.

As with other types of cooking devices, the leading causes of structure fires involving charcoal-fueled grills are unattended cooking and placing combustibles too close to heat. In structure fires, the first items ignited are most commonly the exterior trim and wall coverings. The leading cause of gas-grill fires is attributed to failure of the equipment or breaks in the gas lines of the equipment.

Before firing up the grill, there are several safety precautions and fire code requirements to keep in mind. By following these guidelines, you'll help prevent possible gas explosions or fires.



Here are a few tips that can help make barbecuing safer.

- Charcoal briquettes should be stored in a dry area because damp or wet charcoal is sensitive to spontaneous heating.
- The use and storage of barbecue grills should be restricted to the out-of-doors. Never use barbecue grills for home heating or indoor cooking.
- Charcoal briquettes should be allowed to cool naturally a safe distance from structures and combustible materials and then properly disposed of.
- Charcoal lighter fluid should be properly stored, away from ng areas of the home.

- Propane cylinders should be stored outside at least 20 feet from building openings such as windows and doors.
- Check grill hoses for cracking, brittleness, holes, and leaks. Make sure there are no sharp bends in the hose or tubing.
- Never bring the propane tank into the house. Store cylinders and grills with cylinders attached in a shaded, cool area out of direct sunlight.
- Charcoal and gas grills are sources of Carbon Monoxide. CO fumes are odorless and can quickly overwhelm you in an enclosed space.
- Use only LP containers equipped with an Overfill Protection Device

The state of Vermont recently adopted the 2003 NFPA Uniform Fire Code that includes regulations concerning grills on and near combustible decks and structures. The new code contains the following code requirements concerning these appliances.

SAFETY CODE

For other than one- and two-family dwellings, no hibachi, gas-fired grill, charcoal grill, or other similar devices used for cooking, heating, or any other purpose, shall be used or kindled on any balcony or under any overhanging portion or within **10 ft (3 m)** of any structure. Listed electric ranges, grills, or similar electrical apparatus shall be permitted.

[NFPA 1 : Sec10.11.7]

Open fires and cooking fires shall be constantly attended by a competent person until such fire is extinguished. This person shall have a garden hose connected to the water supply or other fire-extinguishing equipment readily available for use.

[NFPA 1 : Sec10.11.3]

Anytime you're dealing with a force as explosive as several sticks of dynamite, caution must be taken. The propane cylinders that are used to fuel gas grills are just this explosive.

For your own safety, take the time to learn how to handle them safely.